

A9
209
2"
14.7

A10
285
2"
14.7
A3
209
2"
30.6

A8	A2
304	209
2"	2"
14.7	30.6

**WATER REQUIREMENT**  
WATER REQUIREMENT AT  
-FIELD ELEVATION  
-WITHIN 30m OF FIELD  
-DOWNSTREAM OF  
-BACKFLOW IS 304 l/min @  
3.86 Bars

### IRRIGATION LEGEND

- PRODUCT DESCRIPTION**
- HUNTER I20-36S-XX/I20-36S-XX, NOZZLE AS SHOWN
  - HUNTER I20-ADS-XX/I20-ADS-XX, NOZZLE AS SHOWN
  - NOZZLE PERFORMANCE:  
#5 @ 3.0 Bars - 19.0 l/min 12.3m RADIUS
  - HUNTER IGV/BV ELECTRIC CONTROL VALVE SIZE AS SHOWN
  - HUNTER HCC44-XX-XXV QUICK COUPLER VALVE (OPTIONAL)
  - HUNTER ACC-I200-4V SOLID STATE METAL CABINET CONTROLLER
  - HUNTER SOLAR-SYNC-SEN ON SITE WEATHER SENSOR
  - WATER METER MINIMUM SIZE @ 304 l/min IS 63mm
  - BACKFLOW PREVENTER SIZED TO SYSTEM l/min
  - MANLINE PIPE
  - LATERAL PIPE
  - SLEEVING
  - ISOLATION VALVE LINE SIZED
  - HUNTER FLOW SENSOR IN LINE SIZED FLOW CLIK TEE "FCT"

### IRRIGATION NOTES

1. SPRINKLER LOCATIONS ARE TO SCALE
2. PIPE LOCATIONS ARE DIAGRAMMATIC
3. ALL SPRINKLERS TO BE INSTALLED ON 25mm SCH 80 SWING JOINTS
4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
5. MAINLINE DEPTH TO BE NO LESS THAN 460mm
6. LATERAL DEPTH TO BE NO LESS THAN 410mm
7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
8. LOCATE VALVES/OCV'S OUT OF HIGH TRAFFIC AREAS
9. WIRE SPICE CONNECTIONS TO BE WATERPROOF
10. OCV TO BE LOCATED IN 10" VALVE BOX
11. ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
12. INSTALL ALL COMPONENTS AS PER LOCAL, STATE, FEDERAL CODES
13. REFER TO HUNTER INSTALLATION DETAILS
14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
15. ADD HUNTER "FS" FOR DIRTY WATER VALVE
16. ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

### VALVE ID GUIDE




STATION NUMBER
A1
273
1.5"
VALVE SIZE
19
PRECIPITATION RATE mm/hr

### SYSTEM PERFORMANCE DATA

ZONE	SIZE	FLOW m <sup>3</sup> /hr	PR mm/hr	DU	SC (% WINDOW)
A1	1.5"	6.84	114	15.8	.80
A2	1.5"	6.84	114	15.8	.80
A3	2"	16.0	266	15.8	.80
A4	2"	16.0	266	15.8	.80
A5	2"	18.2	304	7.9	.80
A6	2"	17.1	285	7.9	.80
A7	1.5"	13.7	228	7.9	.80
A8	2"	18.2	304	7.9	.80
A9	1.5"	13.7	228	7.9	.80
A10	2"	17.1	285	7.9	.80
A11	2"	18.2	304	7.9	.80

A6
285
2"
30.6
A5
114
2"
30.6
A1
228
2"
30.6

A7
209
2"
14.7



A4
385
A4
30.6

Hunter Industries offers this plan as a general guide for estimating purposes and offers no indemnity expressed or implied, for projects installed from this plan. Because of the many variables of every system and of every site we recommend that a qualified irrigation designer be consulted.

AUSTRALIAN FOOTBALL FIELD

I-20 THIRTEEN ROW DESIGN  
LOOPED MAINLINE

**Hunter®**

Hunter Industries  
1950 Diamond Street  
San Marcos, California 92078  
SpecPro Technical Assistance  
1-800-319-4796  
www.HunterIndustries.com

SHEET

1 OF 1