



- ### IRRIGATION LEGEND
- PRODUCT DESCRIPTION**
- HUNTER I-40-04-SS-ON-XX/I-40-06-SS-ON-XX, NOZZLE AS SHOWN
 - HUNTER I-40-04-SS-XX/I-40-06-SS-XX, NOZZLE AS SHOWN
 - NOZZLE PERFORMANCE: #15 @ 80 PSI - 18.2 GPM 59 RADIUS #18 @ 80 PSI - 17.8 GPM 62 RADIUS
 - HUNTER ICVIBV/ELECTRIC CONTROL VALVE SIZE AS SHOWN
 - HUNTER HQ44-XX-AW QUICK COUPLER VALVE (OPTIONAL)
 - HUNTER ACC-1200 SOLID STATE METAL CABINET CONTROLLER
 - HUNTER SOLAR-SYNC-SEN ON SITE WEATHER SENSOR
 - WATER METER MINIMUM SIZE @ 91.0 GPM IS 2.0"
 - BACKFLOW PREVENTER SIZED TO SYSTEM GPM
 - MAINLINE PIPE
 - LATERAL PIPE
 - SLEEVING
 - ⊗ ISOLATION VALVE LINE SIZED
 - ⊗ HUNTER FLOW SENSOR IN LINE SIZED FLOW CLIK TEE "FCT"

- ### IRRIGATION NOTES
1. SPRINKLER LOCATIONS ARE TO SCALE
 2. PIPE LOCATIONS ARE DIAGRAMMATIC
 3. ALL SPRINKLERS TO BE INSTALLED ON 1" SCH 80 SWING JOINTS
 4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
 5. MAINLINE DEPTH TO BE NO LESS THAN 18"
 6. LATERAL DEPTH TO BE NO LESS THAN 16"
 7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
 8. LOCATE VALVES/OCVS OUT OF HIGH TRAFFIC AREAS
 9. WIRE SPICE CONNECTIONS TO BE WATERPROOF
 10. OCV TO BE LOCATED IN 10" VALVE BOX
 11. ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
 12. INSTALL ALL COMPONENTS AS PER LOCAL, STATE, FEDERAL CODES
 13. REFER TO HUNTER INSTALLATION DETAILS
 14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
 15. ADD HUNTER "FS" FOR DIRTY WATER VALVE
 16. ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

SYSTEM PERFORMANCE DATA

ZONE	SIZE	FLOW	PR	DU	SC _{70%RAIN}
A1	2"	91.0	1.02"	.82	1.2
A2	2"	91.0	1.02"	.82	1.2
A3	1.5"	36.4	2.04"	.82	1.2
A4	1.5"	36.4	2.04"	.82	1.2
A5	1.5"	36.4	2.04"	.82	1.2
A6	2"	91.0	1.02"	.82	1.2
A7	1.5"	53.4	.52"	.81	1.2
A8	2"	89	.52"	.81	1.2
A9	2"	89	.52"	.81	1.2
A10	2"	89	.52"	.81	1.2
A11	1.5"	53.4	.52"	.81	1.2



Hunter Industries offers this plan as a general guide for estimating purposes and offers no indemnity, expressed or implied, for projects installed from this plan. Because of the many variables of every system and of every site we recommend that a qualified irrigation designer be consulted.

