

1. MINIMUM CLEARANCE FOR DOOR OPENING
2. MINIMUM VERTICAL CLEARANCE NEEDED FOR HINGE PIN REMOVAL
3. MODEL IC-XX00-PL
4. SOIL CLIK MODULE AND PROVIDED CABLE
5. SOIL CLIK WIRE CONDUIT, 20mm SIZE.
6. 20mm TEE FOR SOIL CLIK SENSOR CABLE
7. TWO (2) WIRES TO PROBE
8. CONTROL WIRE IN ELECTRICAL CONDUIT. SIZE AND TYPE PER LOCAL CODE
9. 16mm POWER SUPPLY CONDUIT J-BOX INSIDE CONTROLLER CONNECT PER LOCAL CODE

XX

I-CORE CONTROLLER WITH SOIL CLIK
WALL MOUNT

SCALE: N.T.S.

Hunter® IRRIGATION DETAIL