



WATER REQUIREMENT

AT FIELD ELEVATION
-WITHIN 100' OF FIELD
-DOWNSTREAM OF
BACKFLOW IS 96 GPM @ 90
PSI

IRRIGATION LEGEND

- PRODUCT DESCRIPTION**
- HUNTER I40-04-SS-ON-XX/I40-06-SS-ON-XX NOZZLE AS SHOWN
 - HUNTER I40-04-SS-XX/I40-06-SS-XX NOZZLE AS SHOWN
 - HUNTER I40-04-SS-HS-XX/I40-06-SS-HS-XX NOZZLE AS SHOWN
- NOZZLE PERFORMANCE:**
- #8 @ 80 PSI - 10.0 GPM 47" RADIUS
 - #10 @ 80 PSI - 13.0 GPM 52" RADIUS
 - #13 @ 80 PSI - 14.2 GPM 53" RADIUS
 - #15 @ 80 PSI - 18.2 GPM 59" RADIUS
 - #23 @ 80 PSI - 24.5 GPM 65" RADIUS
 - #23ON @ 80 PSI - 24.0 GPM 67" RADIUS
- VALVE AND SENSOR NOTATIONS:**
- ⊗ HUNTER ICV/BEV ELECTRIC CONTROL VALVE SIZED AS SHOWN
 - ⊙ HUNTER HQ-44-XX-AW QUICK COUPLER VALVE (OPTIONAL)
 - ⊕ HUNTER ACC-1800 SOLID STATE METAL CABINET CONTROLLER
 - ⊖ HUNTER SOLAR-SS-NC-SEN ON SITE WEATHER SENSOR
 - ⊞ WATER METER MINIMUM SIZE @ 96 GPM IS 2.0"
 - ⊟ BACKFLOW PREVENTER SIZED TO SYSTEM GPM
 - MAINLINE PIPE
 - - - LATERAL PIPE
 - ≡≡≡ SLEEVING
 - ⊠ ISOLATION VALVE LINE SIZED
 - ⊡ HUNTER FLOW SENSOR IN LINE SIZED FLOW CLK TEE "FCT"

IRRIGATION NOTES

- SPRINKLER LOCATIONS ARE TO SCALE
- PIPE LOCATIONS ARE DIAGRAMMATIC
- ALL SPRINKLERS TO BE INSTALLED ON 1" SCH 80 SWING JOINTS
- ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
- MAINLINE DEPTH TO BE NO LESS THAN 18"
- LATERAL DEPTH TO BE NO LESS THAN 16"
- ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
- LOCATE VALVES/QCV'S OUT OF HIGH TRAFFIC AREAS
- WIRE SPLICE CONNECTIONS TO BE WATERPROOF
- OCV TO BE LOCATED IN 10" VALVE BOX
- ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
- INSTALL ALL COMPONENTS AS PER LOCAL STATE FEDERAL CODES
- REFER TO HUNTER INSTALLATION DETAIL S
- REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
- ADD HUNTER "FCT" FOR DIRTY WATER VALVE
- ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

VALVE ID GUIDE SYSTEM PERFORMANCE DATA

STATION NUMBER	ZONE	SIZE	FLOW	PR	DU	SC
A1	1.5"	52	62"	7.4	1.3	
A2	1.5"	65	91"	8.5	1.2	
A3	1.5"	52	91"	8.2	1.3	
A4	1.5"	65	91"	8.5	1.2	
A5	2"	91	87"	8.4	1.2	
A6	1.5"	42.6	97"	8.8	1.1	
A7	1.5"	28	97"	8.8	1.1	
A8	2"	42.6	136"	7.7	1.3	
A9	1.5"	73.5	129"	8.0	1.3	
A10	1.5"	73.5	129"	8.0	1.3	
A11	1.5"	72	55"	8.1	1.3	
A12	2"	96	55"	8.1	1.3	
A13	1.5"	72	55"	8.1	1.3	
A14	1.5"	72	55"	8.1	1.3	
A15	1.5"	72	55"	8.1	1.3	
A16	1.5"	94.6	59"	8.1	1.3	

Hunter Industries offers this plan as a general guide for estimating purposes and offers no indemnity, expressed or implied, for projects installed from this plan. Because of the many variables of every system and of every site we recommend that a qualified irrigation designer be consulted.



OFFICIAL BASEBALL FIELD
I-40 FOUR ROW DESIGN
LOOPED MAINLINE

Hunter Industries
1940 Diamond Street
San Marcos, California 92078
SpecPro Technical Assistance
1-800-319-4796
www.HunterIndustries.com

SHEET
1 OF 1