

| | |
|------|------|
| A8 | A2 |
| 304 | 209 |
| 2" | 2" |
| 14.7 | 30.6 |

WATER REQUIREMENT

WATER REQUIREMENT AT
-FIELD ELEVATION
-WITHIN 30m OF FIELD
-DOWNSTREAM OF
BACKFLOW IS 304 l/min @
3.86 Bars

IRRIGATION LEGEND

- PRODUCT DESCRIPTION
HUNTER I-20-04-SS-XXI-20-06-SS-XX, NOZZLE AS SHOWN
- NOZZLE PERFORMANCE:
#5.0 @ 3.0 Bars - 19.0 l/min 12.3m RADIUS
- ⊕ HUNTER IGV/B/ELECTRIC CONTROL VALVE SIZE AS SHOWN
- ⊗ HUNTER HQ44-XX-4W/QUICK COUPLER VALVE (OPTIONAL)
- ⊙ HUNTER ACC-1200-4W/SOLID STATE METAL CABINET CONTROLLER
- ⊕ HUNTER SOLAR-SYNG-SEN ON SITE WEATHER SENSOR
- ⊕ WATER METER MINIMUM SIZE @ 304 l/min IS 63mm
- ⊕ BACKFLOW PREVENTER SIZED TO SYSTEM l/min
- ⊕ MAINLINE PIPE
- ⊕ LATERAL PIPE
- ⊕ SLEEVING
- ⊕ ISOLATION VALVE LINE SIZED
- ⊕ HUNTER FLOW SENSOR IN LINE SIZED FLOW CLK TEE "FCT"

IRRIGATION NOTES

1. SPRINKLER LOCATIONS ARE TO SCALE
2. PIPE LOCATIONS ARE DIAGRAMMATIC
3. ALL SPRINKLERS TO BE INSTALLED ON 25mm SCH 80 SWING JOINTS
4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
5. MAINLINE DEPTH TO BE NO LESS THAN 460mm
6. LATERAL DEPTH TO BE NO LESS THAN 410mm
7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
8. LOCATE VALVES/COV'S OUT OF HIGH TRAFFIC AREAS
9. WIRE SPICE CONNECTIONS TO BE WATERPROOF
10. COV TO BE LOCATED IN 10" VALVE BOX
11. ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
12. INSTALL ALL COMPONENTS AS PER LOCAL, STATE, FEDERAL CODES
13. REFER TO HUNTER INSTALLATION DETAILS
14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
15. ADD HUNTER "FS" FOR DIRTY WATER VALVE
16. ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

| | |
|-----|------|
| A10 | 286 |
| 2" | 14.7 |
| A3 | 209 |
| 2" | 30.6 |

| | |
|----|------|
| A9 | 209 |
| 2" | 14.7 |

| | |
|----|------|
| A6 | 286 |
| 2" | 30.6 |
| A5 | 114 |
| 2" | 30.6 |
| A1 | 228 |
| 2" | 30.6 |



| | |
|----|------|
| A7 | 209 |
| 2" | 14.7 |

VALVE ID GUIDE

| | |
|------|--------------------------|
| A1 | STATION NUMBER |
| 273 | 75 |
| 1.5" | VALVE SIZE |
| 19 | PRECIPITATION RATE mm/hr |

SYSTEM PERFORMANCE DATA

| ZONE | SIZE | FLOW m ³ /hr | l/min | PR mm/hr | DJ | SC _(15% MINIMUM) |
|------|------|----------------------------|-------|-------------|-----|-----------------------------|
| A1 | 1.5" | 6.84 | 114 | 15.8 | .80 | 1.2 |
| A2 | 1.5" | 6.84 | 114 | 15.8 | .80 | 1.2 |
| A3 | 2" | 16.0 | 266 | 15.8 | .80 | 1.2 |
| A4 | 2" | 16.0 | 266 | 15.8 | .80 | 1.2 |
| A5 | 2" | 18.2 | 304 | 7.9 | .80 | 1.2 |
| A6 | 2" | 17.1 | 285 | 7.9 | .80 | 1.2 |
| A7 | 1.5" | 13.7 | 228 | 7.9 | .80 | 1.2 |
| A8 | 2" | 18.2 | 304 | 7.9 | .80 | 1.2 |
| A9 | 1.5" | 13.7 | 228 | 7.9 | .80 | 1.2 |
| A10 | 2" | 17.1 | 285 | 7.9 | .80 | 1.2 |
| A11 | 2" | 18.2 | 304 | 7.9 | .80 | 1.2 |



| | |
|----|------|
| A4 | 385 |
| A4 | 30.6 |

Hunter Industries offers this plan as a general guide for estimating purposes and offers no indemnity expressed or implied, for projects installed from this plan. Because of the many variables of every system and of every site we recommend that a qualified irrigation designer be consulted.

Hunter Industries
1950 Diamond Street
San Marcos, California 92078
SpecPro Technical Assistance
1-800-319-4796
www.HunterIndustries.com

