


WATER REQUIREMENT

WATER REQUIREMENT AT
-FIELD ELEVATION
-WITHIN 30m OF FIELD
-DOWNSTREAM OF
-BACKFLOW
IS 235 l/min @ 5.89 Bars



IRRIGATION LEGEND

PRODUCT DESCRIPTION

- HUNTER I-20-ADS-XX/I-20-6P-ADS-XX, NOZZLE AS SHOWN
- HUNTER I-35-06-SS-B-XX, NOZZLE AS SHOWN
- HUNTER I-35-06-SS-B-XX, NOZZLE AS SHOWN

NOZZLE PERFORMANCE:

- I-20:
 - #1 @ 3.0 Bars - 4.5 l/min 9.4m RADIUS
 - #1.5 @ 3.0 Bars - 6.2 l/min 10.4m RADIUS
 - #2 @ 3.0 Bars - 7.7 l/min 11.0m RADIUS
- I-35:
 - #12 @ 5.0 Bars - 51.2 l/min 16.8m RADIUS
 - #15 @ 5.0 Bars - 58.8 l/min 17.4m RADIUS

- ➕ HUNTER IGV/BEV ELECTRIC CONTROL VALVE SIZE AS SHOWN
- ➔ HUNTER HQ-44-XX-AW QUICK COUPLER VALVE (OPTIONAL)
- ➔ HUNTER ACC-1200-M SOLID STATE METAL CABINET CONTROLLER
- ➔ HUNTER SOLAR-SYNC-SEN ON SITE WEATHER SENSOR
- ➔ WATER METER MINIMUM SIZE @ 235 l/min IS 50mm
- ➔ BACKFLOW PREVENTER SIZED TO SYSTEM l/min

- MAINLINE PIPE
- LATERAL PIPE
- SLEEVING
- ⊗ ISOLATION VALVE LINE SIZED
- ⊗ HUNTER FLOW SENSOR IN LINE SIZED FLOW CLIK TEE "FCT"

IRRIGATION NOTES

1. SPRINKLER LOCATIONS ARE TO SCALE
2. PIPE LOCATIONS ARE DIAGRAMMATIC
3. ALL SPRINKLERS TO BE INSTALLED ON 32mm SCH 80 SWING JOINTS
4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURERS RECOMMENDATIONS
5. MAINLINE DEPTH TO BE NO LESS THAN 460mm
6. LATERAL DEPTH TO BE NO LESS THAN 410mm
7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
8. LOCATE VALVES/ICV/S OUT OF HIGH TRAFFIC AREAS
9. WIRE SPICE CONNECTIONS TO BE WATERPROOF
10. ICV TO BE LOCATED IN 10" VALVE BOX
11. ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
12. INSTALL ALL COMPONENTS AS PER LOCAL, STATE, FEDERAL CODES
13. REFER TO HUNTER INSTALLATION DETAILS
14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
15. ADD HUNTER "FS" FOR DIRTY WATER VALVE
16. ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

IRRIGATION NOTES

ZONE	SIZE	FLOW m ³ /hr	PR m	DU SC.100/WINDOW	SC.100/WINDOW
A1	1"	1.8	3.1	8.3	1.2
A2	1"	1.8	3.1	8.3	1.3
A3	1.5"	6.2	10.3	25.5	1.1
A4	1.5"	9.2	15.4	14.7	1.1
A5	1.5"	7.1	11.8	54.2	1.2
A6	1.5"	7.1	11.8	54.2	1.2
A7	1.5"	7.1	11.8	54.2	1.2
A8	1.5"	10.6	17.8	8.6	1.2
A9	1.5"	10.6	17.8	8.6	1.2
A10	1.5"	14.9	23.5	11.2	1.1
A11	1.5"	10.6	17.8	8.6	1.1

VALVE ID GUIDE

AI	STATION NUMBER
273	l/min
150	VALVE SIZE
1300	PRECIPITATION RATE mm/hr

