


- ### IRRIGATION LEGEND
- PRODUCT DESCRIPTION
- HUNTER I-35-06-SS-B-XX, NOZZLE AS SHOWN
 - HUNTER I-35-06-SS-B-XX, NOZZLE AS SHOWN
 - NOZZLE PERFORMANCE:
#15 @ 5.5 l/min 17.7m RADIUS
 - HUNTER ICV/IBV ELECTRIC CONTROL VALVE SIZE AS SHOWN
 - HUNTER HQ44-XX-AW QUICK COUPLER VALVE (OPTIONAL)
 - ▲ HUNTER ACC-1200-AM SOLID STATE METAL CABINET CONTROLLER
 - ⚠ HUNTER SOLAR-SYNC-SEN ON SITE WEATHER SENSOR
 - Ⓜ WATER METER MINIMUM SIZE @ 307 l/min IS 63mm
 - Ⓜ BACKFLOW PREVENTER SIZED TO SYSTEM l/min
 - MAINLINE PIPE
 - LATERAL PIPE
 - ===== SLEEVING
 - ⊗ ISOLATION VALVE LINE SIZED
 - ⊗ HUNTER FLOW SENSOR IN LINE SIZED FLOW CLIK TEE "FCT"

- ### IRRIGATION NOTES
1. SPRINKLER LOCATIONS ARE TO SCALE
 2. PIPE LOCATIONS ARE DIAGRAMMATIC
 3. ALL SPRINKLERS TO BE INSTALLED ON 32mm SCH 80 SWING JOINTS
 4. ALL COMPONENTS TO BE INSTALLED AS PER MANUFACTURER'S RECOMMENDATIONS
 5. MAINLINE DEPTH TO BE NO LESS THAN 460mm
 6. LATERAL DEPTH TO BE NO LESS THAN 410mm
 7. ELECTRIC CONTROL VALVES TO BE COVERED WITH 12" VALVE BOX
 8. LOCATE VALVES/QCV'S OUT OF HIGH TRAFFIC AREAS
 9. WIRE SPLICE CONNECTIONS TO BE WATERPROOF
 10. OCV TO BE LOCATED IN 10" VALVE BOX
 11. ALL SLEEVES TO BE 2X PIPE RUN THROUGH THEM
 12. INSTALL ALL COMPONENTS AS PER LOCAL STATE, FEDERAL CODES
 13. REFER TO HUNTER INSTALLATION DETAILS
 14. REFER TO HUNTER CATALOG FOR PERFORMANCE SPECIFICATIONS
 15. ADD HUNTER "FS" FOR DIRTY WATER VALVE
 16. ADD HUNTER "AS" FOR PRESSURE REGULATED VALVE

SYSTEM PERFORMANCE DATA

ZONE	SIZE	FLOW m ³ /hr	PR m ³ /hr	DU	SC (100% WET)
A1	1.5"	18.4	307	.24	.87
A2	1.5"	18.4	307	.24	.87
A3	1.5"	7.38	137	.48	.87
A4	1.5"	18.4	307	.24	.87
A5	1.5"	7.38	137	.48	.87
A6	1.5"	18.4	307	.24	.87
A7	1.5"	18.4	307	.24	.87
A8	1.5"	18.4	307	.24	.87
A9	1.5"	18.4	307	.24	.87
A10	1.5"	18.4	307	.24	.87
A11	1.5"	11.1	185	.12	.87



WATER REQUIREMENT

WATER REQUIREMENT AT
-FIELD ELEVATION
-WITHIN 50m OF FIELD
-DOWNSTREAM OF
BACKFLOW
IS 307 l/min @ 6.86 Bars

VALVE ID GUIDE

A1	STATION NUMBER
273	l/min
4.9	VALVE SIZE
12000	PRECIPITATION RATE mm/hr

A1	A9	A10
307	307	307
1.5"	1.5"	1.5"
24	12	12

A3	A2	A11
123	307	185
1.5"	1.5"	1.5"
48	63	24
12	90	12

Hunter Industries offers this plan as a general guide for estimating purposes and offers no indemnity, expressed or implied, for projects installed from this plan. Disclosure of the many variables of every system and of every site we recommend that a qualified irrigation designer or contractor

RUGBY FIELD

I-35 FIVE ROW DESIGN
LOOPED MAINLINE

SHEET
1 OF 1

Hunter Industries
1940 Diamond Street
San Marcos, California 92078
SpecPro Technical Assistance
1-800-319-4796
www.HunterIndustries.com